

Product Type Approval Certificate

This certificate is issued to:

Supplier:	Raychem (TE Connectivity)
	Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261

In respect of:

Manufacturer:	Raychem (TE Connectivity)
Place of manufacture:	Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261
Product description:	Raychem ESD-7717-AU-3/18 – Size transition joint for 33 kV 1-core polymeric insulated cables with wire screen, 300 mm ² – 630 mm ²
Use approved for:	Transition joint for 33 kV single core 300 mm ² – 630 mm ² XLPE cables without DTS fibres, complying with T HR EL 20001 ST
Product information pack reference	A7102062 (objective reference)
Conditions of approval:	Joint kit shall be installed by staff that are Accredited Cable Jointers in accordance with Sydney Trains document PR-D-78701 <i>Personnel Certifications – Electrical</i> , and trained by TE Connectivity in accordance with the requirements of EP 20 00 03 01 SP
Limitations:	Nil
Notes / Comments:	Nil

Approval

ASA Lead Engineer:	Matthew Percival, Asset Standards Authority
Position:	A / Lead Electrical Engineer
Contact details:	Matthew.Percival@transport.nsw.gov.au
Signature:	
Date:	

[Fill this section only if independent safety assessor is engaged, otherwise mention N/A]

Independent safety assessor:	N/A
Position:	
Contact details:	
Signature:	
Date:	